

10/27/2017

Work Order: 17E1177 Project: Corner Canyon

Canyons School District Attn: Kevin Ray 9361 South 300 East Sandy, UT 84070

Client Service Contact: 801.262.7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Reed Hendricks, Senior Project Manager

www.ChemtechFord.com



Lead, Total

ND

0.015

Certificate of Analysis

						Lab Samp	le No.: 17E1177	-01
Name:	Canyons School District			Sampl	e Date: 5/23/2	017 6:12 AM		
Sample Site:	Auditorium C1			Receipt Date: 5/23/2017 8:20 AM				
Comments:					Sá	ampler: Client		
Sample Matrix:	Drinking Water				F	Project: Corne	r Canyon	
PO Number:					Syste	em No.:		
Source Code:		Sample	Point:		Report to	o State:		J
Parameter	Sample r Result	C	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								

mg/L

EPA 200.8

05/24/2017

05/24/2017



Lead, Total

0.0012

0.015

Certificate of Analysis

						Lab Samp	ole No.: 17E1177	-02
Name:	Canyons School District		Sample	e Date: 5/23/2	2017 6:15 AM			
Sample Site:	Kitchen Prep C2				Receip	t Date: 5/23/2	2017 8:20 AM	
Comments:					Sa	mpler: Client	t	
Sample Matrix:	Drinking Water				P	Project: Corne	er Canyon	
PO Number:					Syste	m No.:		
Source Code:		Sample	Point:		Report to	State:		J
Parameter	Sample C	EPA Max ontaminant evel (MCL)		Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								

mg/L

EPA 200.8

05/24/2017

05/24/2017



Lead, Total

ND

0.015

Certificate of Analysis

						Lab Samp	ole No.: 17E1177	' -0 3
Name:	Canyons School District		Sample	e Date: 5/23/2	2017 6:20 AM			
Sample Site:	Admin Ftn C3			Receipt Date: 5/23/2017 8:20 AM				
Comments:					Sa	mpler: Client	:	
Sample Matrix:	Drinking Water				F	Project: Corne	er Canyon	
PO Number:					Syste	em No.:		
Source Code:		Sample	Point:		Report to	State:		J
Parameter	Sumple	EPA Max Contaminant Level (MCL)		Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								

mg/L

EPA 200.8

05/24/2017

05/24/2017



Lead, Total

ND

0.015

Certificate of Analysis

_		Lab Sample No.: 17E117	7-04
Name: Canyor	ns School District	Sample Date: 5/23/2017 6:25 AM	
Sample Site: C102 C	4	Receipt Date: 5/23/2017 8:20 AM	
Comments:		Sampler: Client	
Sample Matrix: Drinkin	g Water	Project: Corner Canyon	
PO Number:		System No.:	
Source Code:	Sample Point:	Report to State:	
Parameter Metals	EPA Max Minimum Sample Contaminant Reporting Result Level (MCL) Limit	Analytical Preparation Analysis Units Method Date/Time Date/Time	Flag
MCCAIN			

mg/L

EPA 200.8

05/24/2017

05/24/2017



Report Footnotes

Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million. 1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion. 1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards. Values reported in **BLUE** exceed Secondary Drinking Water standards. **BLANK** values in the MCL column indicate no standard.



Certificate of Analysis