



10/27/2017

Work Order: 17E0777
Project: Draper Park

Canyons School District
Attn: Kevin Ray
9361 South 300 East
Sandy, UT 84070

Client Service Contact: 801.262.7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Reed Hendricks, Senior Project Manager



Certificate of Analysis

Lab Sample No.: 17E0777-01

Name: Canyons School District	Sample Date: 5/16/2017 6:10 AM
Sample Site: Kitchen Prep DP1	Receipt Date: 5/16/2017 8:28 AM
Comments:	Sampler: Client
Sample Matrix: Drinking Water	Project: Draper Park
PO Number:	System No.:
Source Code:	Sample Point:
	Report to State:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	0.0023	0.015	0.0005	mg/L	EPA 200.8	05/17/2017	05/17/2017	



Certificate of Analysis

Lab Sample No.: 17E0777-02

Name: Canyons School District	Sample Date: 5/16/2017 6:14 AM
Sample Site: Theatre DP2	Receipt Date: 5/16/2017 8:28 AM
Comments:	Sampler: Client
Sample Matrix: Drinking Water	Project: Draper Park
PO Number:	System No.:
Source Code:	Sample Point:
	Report to State:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/17/2017	05/17/2017	



Certificate of Analysis

Lab Sample No.: 17E0777-03

Name: Canyons School District	Sample Date: 5/16/2017 6:18 AM
Sample Site: 1401 DP3	Receipt Date: 5/16/2017 8:28 AM
Comments:	Sampler: Client
Sample Matrix: Drinking Water	Project: Draper Park
PO Number:	System No.:
Source Code:	Sample Point:
	Report to State:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/17/2017	05/17/2017	



Certificate of Analysis

Lab Sample No.: 17E0777-04

Name: Canyons School District	Sample Date: 5/16/2017 6:21 AM
Sample Site: 2401 DP4	Receipt Date: 5/16/2017 8:28 AM
Comments:	Sampler: Client
Sample Matrix: Drinking Water	Project: Draper Park
PO Number:	System No.:
Source Code:	Sample Point:
	Report to State:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/17/2017	05/17/2017	



Certificate of Analysis

Lab Sample No.: 17E0777-05

Name: Canyons School District	Sample Date: 5/16/2017 6:25 AM
Sample Site: 2701 DP5	Receipt Date: 5/16/2017 8:28 AM
Comments:	Sampler: Client
Sample Matrix: Drinking Water	Project: Draper Park
PO Number:	System No.:
Source Code:	Sample Point:
	Report to State:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/17/2017	05/17/2017	



CHEMTECH-FORD
LABORATORIES

Certificate of Analysis

Report Footnotes

Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.
1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.
1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.
1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards.
Values reported in **BLUE** exceed Secondary Drinking Water standards.
BLANK values in the MCL column indicate no standard.



CHEMTECH-FORD
LABORATORIES

Certificate of Analysis