

10/27/2017

Work Order: 17D0511 Project: Edgemont

Canyons School District Attn: Kevin Ray 9361 South 300 East Sandy, UT 84070

Client Service Contact: 801.262.7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Reed Hendricks, Senior Project Manager

9632 South 500 West Sandy, Utah 84070 801.262.7299 Main 866.792.0093 Fax www.ChemtechFord.com



Lab Sample No.: 17D0511-01

Name: Canyons School District Sample Date: 4/13/2017 6:11 AM

Sample Site: Kitchen Prep E-1 Receipt Date: 4/13/2017 11:10 AM

Comments: Sampler: Client

Sample Matrix: Water Project: Edgemont

PO Number: System No.:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	0.0009	0.015	0.0005	mg/L	EPA 200.8	04/17/2017	04/17/2017	



Lab Sample No.: 17D0511-02

Name: Canyons School District Sample Date: 4/13/2017 6:15 AM

Sample Site: 22 E-2 **Receipt Date:** 4/13/2017 11:10 AM

Comments: Sampler: Client

Sample Matrix: Water Project: Edgemont

PO Number: System No.:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	0.0030	0.015	0.0005	mg/L	EPA 200.8	04/17/2017	04/17/2017	



Lab Sample No.: 17D0511-03

Name: Canyons School District Sample Date: 4/13/2017 6:20 AM

Sample Site: 15 E-3 **Receipt Date:** 4/13/2017 11:10 AM

Comments: Sampler: Client

Sample Matrix: Water Project: Edgemont

PO Number: System No.:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	04/17/2017	04/17/2017	



Lab Sample No.: 17D0511-04

Name: Canyons School District Sample Date: 4/13/2017 6:23 AM

Sample Site: 33 E-4 **Receipt Date:** 4/13/2017 11:10 AM

Comments: Sampler: Client

Sample Matrix: Water Project: Edgemont

PO Number: System No.:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	04/17/2017	04/17/2017	



Lab Sample No.: 17D0511-05

Name: Canyons School District Sample Date: 4/13/2017 6:25 AM

Sample Site: 44 E-5 **Receipt Date:** 4/13/2017 11:10 AM

Comments: Sampler: Client

Sample Matrix: Water Project: Edgemont

PO Number: System No.:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	04/17/2017	04/17/2017	



Lab Sample No.: 17D0511-06

Name: Canyons School District Sample Date: 4/13/2017 6:30 AM

Sample Site: Main Hall E-6 Receipt Date: 4/13/2017 11:10 AM

Comments: Sampler: Client

Sample Matrix: Water Project: Edgemont

PO Number: System No.: Source Code: Sample Point: Report to State:

EPA Max Minimum Sample Contaminant Reporting Analytical Analysis Preparation Result Level (MCL) Limit Method Date/Time Date/Time **Parameter** Units Flag Metals Lead, Total ND 0.015 0.0005 EPA 200.8 04/17/2017 04/17/2017 mg/L

CHEMTECH-FORD

Certificate of Analysis

Report Footnotes

Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million. $1\ ug/L = one\ microgram\ per\ liter\ or\ 1\ ug/Kg = one\ microgram\ per\ kilogram = 1\ part\ per\ billion.$ 1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards. Values reported in **BLUE** exceed Secondary Drinking Water standards. **BLANK** values in the MCL column indicate no standard.

