



10/27/2017

**Work Order: 17E0077**  
**Project: Sandy**

**Canyons School District**  
**Attn: Kevin Ray**  
**9361 South 300 East**  
**Sandy, UT 84070**

**Client Service Contact: 801.262.7299**

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Reed Hendricks, Senior Project Manager



**CHEMTECH-FORD**  
LABORATORIES

## Certificate of Analysis

**Lab Sample No.: 17E0077-01**

**Name:** Canyons School District

**Sample Date:** 5/2/2017 6:05 AM

**Sample Site:** Kitchen Prep S1

**Receipt Date:** 5/2/2017 11:20 AM

**Comments:**

**Sampler:** Client

**Sample Matrix:** Drinking Water

**Project:** Sandy

**PO Number:**

**System No.:**

**Source Code:**

**Sample Point:**

**Report to State:**

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Lead, Total	0.0014	0.015	0.0005	mg/L	EPA 200.8	05/04/2017	05/04/2017	



**CHEMTECH-FORD**  
LABORATORIES

## Certificate of Analysis

**Lab Sample No.: 17E0077-02**

**Name:** Canyons School District

**Sample Date:** 5/2/2017 6:10 AM

**Sample Site:** Play Room S2

**Receipt Date:** 5/2/2017 11:20 AM

**Comments:**

**Sampler:** Client

**Sample Matrix:** Drinking Water

**Project:** Sandy

**PO Number:**

**System No.:**

**Source Code:**

**Sample Point:**

**Report to State:**

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/04/2017	05/04/2017	



**CHEMTECH-FORD**  
LABORATORIES

## Certificate of Analysis

**Lab Sample No.: 17E0077-03**

**Name:** Canyons School District

**Sample Date:** 5/2/2017 6:13 AM

**Sample Site:** Custodial S3

**Receipt Date:** 5/2/2017 11:20 AM

**Comments:**

**Sampler:** Client

**Sample Matrix:** Drinking Water

**Project:** Sandy

**PO Number:**

**System No.:**

**Source Code:**

**Sample Point:**

**Report to State:**

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/04/2017	05/04/2017	



**CHEMTECH-FORD**  
LABORATORIES

## Certificate of Analysis

**Lab Sample No.: 17E0077-04**

**Name:** Canyons School District

**Sample Date:** 5/2/2017 6:15 AM

**Sample Site:** SE Hall S4

**Receipt Date:** 5/2/2017 11:20 AM

**Comments:**

**Sampler:** Client

**Sample Matrix:** Drinking Water

**Project:** Sandy

**PO Number:**

**System No.:**

**Source Code:**

**Sample Point:**

**Report to State:**

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/04/2017	05/04/2017	



CHEMTECH-FORD  
LABORATORIES

## Certificate of Analysis

Lab Sample No.: 17E0077-05

**Name:** Canyons School District

**Sample Date:** 5/2/2017 6:18 AM

**Sample Site:** NE Hall S5

**Receipt Date:** 5/2/2017 11:20 AM

**Comments:**

**Sampler:** Client

**Sample Matrix:** Drinking Water

**Project:** Sandy

**PO Number:**

**System No.:**

**Source Code:**

**Sample Point:**

**Report to State:**

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Lead, Total	0.0006	0.015	0.0005	mg/L	EPA 200.8	05/04/2017	05/04/2017	



**CHEMTECH-FORD**  
LABORATORIES

## Certificate of Analysis

**Lab Sample No.: 17E0077-06**

**Name:** Canyons School District

**Sample Date:** 5/2/2017 6:22 AM

**Sample Site:** Upper N Hall S6

**Receipt Date:** 5/2/2017 11:20 AM

**Comments:**

**Sampler:** Client

**Sample Matrix:** Drinking Water

**Project:** Sandy

**PO Number:**

**System No.:**

**Source Code:**

**Sample Point:**

**Report to State:**

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/04/2017	05/04/2017	



CHEMTECH-FORD  
LABORATORIES

## Certificate of Analysis

### Report Footnotes

#### Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.

1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.

1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

#### Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards.

Values reported in **BLUE** exceed Secondary Drinking Water standards.

**BLANK** values in the MCL column indicate no standard.





**CHEMTECH-FORD**  
LABORATORIES

## Certificate of Analysis