

10/27/2017

Work Order: 17E0370 Project: Willow Canyon

Canyons School District Attn: Kevin Ray 9361 South 300 East Sandy, UT 84070

Client Service Contact: 801.262.7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Reed Hendricks, Senior Project Manager

9632 South 500 West Sandy, Utah 84070 801.262.7299 Main 866.792.0093 Fax www.ChemtechFord.com



Lab Sample No.: 17E0370-01

Name: Canyons School District Sample Date: 5/8/2017 6:10 AM

Sample Site: Main Hall W1 Receipt Date: 5/8/2017 9:15 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Willow Canyon

PO Number: System No.:

Pa	Sample Result	EPA Max Contaminant Level (MCL)		Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	 ND	0.015	0.0005	mg/L	EPA 200.8	05/10/2017	05/10/2017	



Lab Sample No.: 17E0370-02

Name: Canyons School District Sample Date: 5/8/2017 6:15 AM

Sample Site: Kitchen Prep W2 Receipt Date: 5/8/2017 9:15 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Willow Canyon

PO Number: System No.:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	0.0016	0.015	0.0005	mg/L	EPA 200.8	05/10/2017	05/10/2017	



Lab Sample No.: 17E0370-03

Name: Canyons School District Sample Date: 5/8/2017 6:17 AM

Sample Site: N West Hall W3 Receipt Date: 5/8/2017 9:15 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Willow Canyon

PO Number: System No.:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/10/2017	05/10/2017	



Lab Sample No.: 17E0370-04

Name: Canyons School District Sample Date: 5/8/2017 6:20 AM

Sample Site: S W Hall W4 Receipt Date: 5/8/2017 9:15 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Willow Canyon

PO Number: System No.:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/10/2017	05/10/2017	



Lab Sample No.: 17E0370-05

Name: Canyons School District Sample Date: 5/8/2017 6:24 AM

Sample Site: South Hall W5 Receipt Date: 5/8/2017 9:15 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Willow Canyon

PO Number: System No.:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/10/2017	05/10/2017	



Lab Sample No.: 17E0370-06

Name: Canyons School District Sample Date: 5/8/2017 6:27 AM

Sample Site: East Hall W6 Receipt Date: 5/8/2017 9:15 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Willow Canyon

PO Number: System No.:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	05/10/2017	05/10/2017	



Lab Sample No.: 17E0370-07

Name: Canyons School District Sample Date: 5/8/2017 6:33 AM

Sample Site: Kindergarten W7 Receipt Date: 5/8/2017 9:15 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Willow Canyon

PO Number: System No.:

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Lead, Total	0.0006	0.015	0.0005	mg/L	EPA 200.8	05/10/2017	05/10/2017	

# CHEMTECH-FORD

## **Certificate of Analysis**

# **Report Footnotes**

### **Abbreviations**

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million. 1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion. 1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

### **Data Comparisons**

Values reported in **RED** exceed Primary Drinking Water standards. Values reported in **BLUE** exceed Secondary Drinking Water standards. **BLANK** values in the MCL column indicate no standard.

