

5/2/2018

Work Order: 18D1233 Project: Midvale Middle

Canyons School District Attn: Kevin Ray 9361 South 300 East Sandy, UT 84070

Client Service Contact: 801.262.7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Dave Gayer, Laboratory Director

9632 South 500 West Sandy, Utah 84070 801.262.7299 Main 866.792.0093 Fax *www.ChemtechFord.com* 



Lab Sample No.: 18D1233-01

Name: Canyons School District Sample Date: 4/25/2018 6:03 AM

Sample Site: Kitchen Prep M-1 Receipt Date: 4/25/2018 8:05 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Midvale Middle

PO Number: System No.: UTAH18000

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.723	1.3	0.0010	mg/L	EPA 200.8	04/26/2018	04/26/2018	
Iron, Total	ND	0.3	0.02	mg/L	EPA 200.7	04/26/2018	04/26/2018	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	04/26/2018	04/26/2018	



Lab Sample No.: 18D1233-02

Name: Canyons School District Sample Date: 4/25/2018 6:06 AM

Sample Site: Cafe Hall M-2 Receipt Date: 4/25/2018 8:05 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Midvale Middle

PO Number: System No.: UTAH18000

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.597	1.3	0.0010	mg/L	EPA 200.8	04/26/2018	04/26/2018	
Iron, Total	ND	0.3	0.02	mg/L	EPA 200.7	04/26/2018	04/26/2018	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	04/26/2018	04/26/2018	



Lab Sample No.: 18D1233-03

Name: Canyons School District Sample Date: 4/25/2018 6:07 AM

Sample Site: Yellow Hall M-3 Receipt Date: 4/25/2018 8:05 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Midvale Middle

PO Number: System No.: UTAH18000

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.154	1.3	0.0010	mg/L	EPA 200.8	04/26/2018	04/26/2018	
Iron, Total	ND	0.3	0.02	mg/L	EPA 200.7	04/26/2018	04/26/2018	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	04/26/2018	04/26/2018	



Lab Sample No.: 18D1233-04

Name: Canyons School District Sample Date: 4/25/2018 6:10 AM

 Sample Site:
 Gym M-4

 Receipt Date:
 4/25/2018

 8:05 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Midvale Middle

PO Number: System No.: UTAH18000

Pa	'arameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals									
Copper, Total		0.421	1.3	0.0010	mg/L	EPA 200.8	04/26/2018	04/26/2018	
Iron, Total		ND	0.3	0.02	mg/L	EPA 200.7	04/26/2018	04/26/2018	
Lead, Total		ND	0.015	0.0005	mg/L	EPA 200.8	04/26/2018	04/26/2018	



Lab Sample No.: 18D1233-05

Name: Canyons School District Sample Date: 4/25/2018 6:12 AM

Sample Site: Green Hall M-5 Receipt Date: 4/25/2018 8:05 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Midvale Middle

PO Number: System No.: UTAH18000

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.126	1.3	0.0010	mg/L	EPA 200.8	04/26/2018	04/26/2018	
Iron, Total	ND	0.3	0.02	mg/L	EPA 200.7	04/26/2018	04/26/2018	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	04/26/2018	04/26/2018	



Lab Sample No.: 18D1233-06

Name: Canyons School District Sample Date: 4/25/2018 6:15 AM

Sample Site: Orange Hall M-6 Receipt Date: 4/25/2018 8:05 AM

Comments: Sampler: Client

Sample Matrix: Drinking Water Project: Midvale Middle

**PO Number:** System No.: UTAH18000

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.342	1.3	0.0010	mg/L	EPA 200.8	04/26/2018	04/26/2018	
Iron, Total	ND	0.3	0.02	mg/L	EPA 200.7	04/26/2018	04/26/2018	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	04/26/2018	04/26/2018	

# CHEMTECH-FORD

# **Certificate of Analysis**

# **Report Footnotes**

#### **Abbreviations**

ND = Not detected at the corresponding Minimum Reporting Limit.

- 1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.
- $1\ ug/L = one\ microgram\ per\ liter\ or\ 1\ ug/Kg = one\ microgram\ per\ kilogram = 1\ part\ per\ billion.$
- 1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

#### **Data Comparisons**

Values reported in RED exceed Primary Drinking Water standards. Values reported in BLUE exceed Secondary Drinking Water standards. BLANK values in the MCL column indicate no standard.

#### CHEMTECH - FORD ANALYTICAL LABORATORY CHAIN OF CUSTODY Garyous School District 9361 South 300 Fast COMPANY: **BILLING ADDRESS:** ADDRESS: BILLING CITY/STATE/ZIP: CITY/STATE/ZIP: U+94 94070 **PURCHASE ORDER #:** PHONE #: FAX: **INVOICE EMAIL ADDRESS:** CONTACT: PROJECT: EMAIL: TURNAROUND REQUIRED:\* \* Expedited turnaround subject to additional charge TESTS REQUESTED. Bacteria 🗥 (otal Coliform + E. coli (Enumerated) fotal Coliform + E. coli (Present/Al HPC (Plate Count) Lab Use Only CLIENT SAMPLE INFORMATION LOCATION / IDENTIFICATION TIME MATRIX -01 4-25-18 06:03 Wz fen -02 06:06 -03 06:07 -04 06:10 -nS 06:12 06:15 Sampled by: [print] Sampled by: [signature] NOT ON ICE Temp (C'): Special Instructions:

08:05

Received by: [signature]

Relinquished by: [signature]

Relinquished by: [signature]

Relinquished by: [signature]

801 262 7200 PUONE

Date/Time

Date/Time

Date/Time

9632 South 500 West Sandy, UT 84070

CHEMTECH-FORD

801.262.7299 PHONE 866.792.0093 FAX www.chemtechford.com

Payment Terms are net 30 days OAC. 1.5% interest charge per month (18% per annum). Client agress to pay collection costs and attorney's fees.

Samples received outside the EPA recommended temperature range of 0-6 C\* may be rejected.

Date/Time

Date/Time

# Work Order # <u>D1233</u>

#### **CHEMTECH FORD LABORATORIES**

Sample Receipt



#### **Delivery Method:**

□ UPS □ USPS

☐ FedEx ☐ Chemtech Courier

Walk-in ☐ Customer Courier

Receiving Temperature 15.2 c

			Ē	Ì	celvi	Š		
Sample #	Container M	Chemtech Lot # or Preservative	Number of Subsem	Preserved by Clie	reserved in Receiv	Filtered in Field by C	Misc Volume (oz/mL)	Comments
-01-06	M	843						
		,						
<del></del>			$\Box$					
				Г				
				<u> </u>				
				Г				
								······································

Sample Condition (check if yes)	
☐ Custody Seals	
Containers Intact	
COC/Labels Agree	
Preservation Confirmed	
Received on Ice	
Correct Containers(s)	
Sufficent Sample Volume	
☐ Headspace Present (VOC)	
☐ Temperature Blank	
Received within Holding Tim	e

### Plastic Containers

- A- Plastic Unpreserved
- B- Miscellaneous Plastic
- C- Cyanide Qt (NaOH)
- E- Coliform/Ecoli/HPC F- Sulfide Qt (Zn Acetate)
- L- Mercury 1631
- M- Metals Pint (HNO3)
- N- Nutrient Pint (H2SO4)
- R- Radiological (HNO3)
- S- Sludge Cups/Tubs
- Q- Plastic Bag

#### **Glass Containers**

- D- 625 (Na2S2O3)
- G-Glass Unpreserved
- H- HAAs (NH4CI)
- J- 508/515/525 (Na2SO3)
- K- 515.3 Herbicides
- O- Oil & Grease (HCl)
- P- Phenois (H2SO4)
- T- TOC/TOX (H3PO4)
- U- 531 (MCAA, Na2S2O3)
- V- 524/THMs (Ascorbic Acid) W- 8260 VOC (1:1 HCl)
- X- Vial Unpreserved
- Y- 624/504 (Na2S2O3)
- Z- Miscellaneous Glass