



5/17/2018

**Work Order: 18E0648**  
**Project: Silver Mesa Elementary**

**Canyons School District**  
**Attn: Kevin Ray**  
**9361 South 300 East**  
**Sandy, UT 84070**

**Client Service Contact: 801.262.7299**

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Dave Gayer, Laboratory Director



### Certificate of Analysis

Lab Sample No.: 18E0648-01

<b>Name:</b> Canyons School District	<b>Sample Date:</b> 5/11/2018 5:45 AM
<b>Sample Site:</b> Kitchen Prep SM-3	<b>Receipt Date:</b> 5/11/2018 10:45 AM
<b>Comments:</b>	<b>Sampler:</b> Client
<b>Sample Matrix:</b> Water	<b>Project:</b> Silver Mesa Elementary
<b>PO Number:</b>	<b>System No.:</b> UTAH18000
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Lead, Total	0.0094	0.015	0.0005	mg/L	EPA 200.8	05/14/2018	05/14/2018	



### Certificate of Analysis

Lab Sample No.: 18E0648-02

<b>Name:</b> Canyons School District	<b>Sample Date:</b> 5/11/2018 5:50 AM
<b>Sample Site:</b> Kitchen Prep SM-2H	<b>Receipt Date:</b> 5/11/2018 10:45 AM
<b>Comments:</b>	<b>Sampler:</b> Client
<b>Sample Matrix:</b> Water	<b>Project:</b> Silver Mesa Elementary
<b>PO Number:</b>	<b>System No.:</b> UTAH18000
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Lead, Total	0.0058	0.015	0.0005	mg/L	EPA 200.8	05/14/2018	05/14/2018	



### Certificate of Analysis

Lab Sample No.: 18E0648-03

<b>Name:</b> Canyons School District	<b>Sample Date:</b> 5/11/2018 6:02 AM
<b>Sample Site:</b> Kitchen Prep SM-2C	<b>Receipt Date:</b> 5/11/2018 10:45 AM
<b>Comments:</b>	<b>Sampler:</b> Client
<b>Sample Matrix:</b> Water	<b>Project:</b> Silver Mesa Elementary
<b>PO Number:</b>	<b>System No.:</b> UTAH18000
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Lead, Total	0.0027	0.015	0.0005	mg/L	EPA 200.8	05/14/2018	05/14/2018	



## Certificate of Analysis

### Report Footnotes

#### Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.

1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.

1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

#### Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards.

Values reported in **BLUE** exceed Secondary Drinking Water standards.

**BLANK** values in the MCL column indicate no standard.



